

Risk Assessment



Area	H & S	Date	16.06.22	Assessment number	IC/BE/L
------	-------	------	----------	-------------------	---------

Staff responsible	CM	Review Date	16.06.23
-------------------	----	-------------	----------

Task	LEGIONELLA (Low Risk premises - B/W Clinic & Offices)
------	---

Risk Number	Risk Description	Effects/ Impact on	Existing controls	Risk Rating			Further action required/ action plan	By Whom	Date	Cross reference categories	Risk with Mitigation	Update
				Impact (I)	Likelihood (L)	Rating						
1	Danger to all staff, students, contractors patients, visitors & vulnerable persons from getting legionaires disease.	All staff, students, contractors patients, visitors & vulnerable persons	Mains fed water, no water points shared (no mixer taps), no water storage tanks, handwash basins only. Protocol for flushing taps on return after closures.	High	Possible	High 8	None				Low (1 - 3)	